



4900 River Oaks Boulevard  River Oaks, Texas  76114

Mayor
Herman D. Earwood

City Council
Mayor Pro Tem/Place 2
Steve Holland

Place 1
JoAnn Butler

Place 3
Bruce Scott

Place 4
Joe Ashton

Place 5
JoAnn Gordon

City Secretary
Marvin Gregory

Fire Chief
Russell Shelley

Police Chief
Avin Carter

Public Works Supt.
Fabian Neathery

Library Director
Veronica Clark

Phone
(817) 626-5421

Fax
(817) 624-2154

Website
www.riveroakstx.com

April 27, 2016

Dear River Oaks Water Customer:

MANDATORY LANGUAGE FOR A MAXIMUM CONTAMINANT LEVEL VIOLATION
MCL, LRAA/TOTAL HALOACETIC ACIDS (HAA5)

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF RIVER OAKS TX2200069 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for haloacetic acids (group of five). The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for haloacetic acids (group of five) to be 0.060 milligrams per liter (mg/L) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for haloacetic acids (group of five) indicates a compliance value in quarter one 2016 of 0.061 mg/L for DBP2-01 and 0.089 mg/L for DBP2-02.

Haloacetic Acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with the naturally-occurring organic matter in the water.

Some people who drink water containing **HAA5** in excess of the MCL **over many years** may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: On March 1, 2016 the City Engineer based on their research of the water plant's operating procedure reported that the proper chemical dosage was being used and that final water quality from the plant was excellent. In conclusion, the engineer recommended that the city do extensive flushing of the entire water distribution system associated with low water usage from the water distribution system common this time of the year. Lastly, the city has requested assistance from the TCEQ in addressing maximum contaminant level exceedances for haloacetic acids (HAA5).

Please share this information with all people who drink this water, especially those that may not have received this notice directly (i.e. people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions concerning this matter, you may contact **Marvin Gregory at 817-626-5421, extension 324**. *Este aviso también está disponible en español. Para obtener más información, póngase en contacto con Lourdes Torres al 817-626-5421, extensión 315.*

Posted/Delivered on: April 28, 2016

Marvin C. Gregory III
City of River Oaks